



GENERAL NOTES:

- ANCHORAGE TO CONCRETE WALL OR SOLID BRICK, USE HILTI KWIK BOLT IF EXPANSION ANCHORS 3/8" Ø (MIN.)
- ANCHORAGE TO HOLLOW CONCRETE BLOCK, USE HILTI TOGGLE BOLT (CARBON STEEL) 1/2" Ø (MIN.)
- ANCHORAGE TO METAL STUDS AND GYP. BOARD WALLS, USE CARBON STEEL THROUGH BOLT, 3/8" Ø (MIN.)
- PROVIDE CARBON STEEL STRUCTURAL STEEL ANGLES, BARS & SHEET PER ASTM A36.
- WELD PER AWS D1.1, STRUCTURAL STEEL.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERSED INTO A DRAWING PACK-AGE).

NO.	DATE	REVISION	BY	ML	CL	TO
1	6-11-01	1	GENERAL REVIEW			
2	10-11-01	1	REWORK			

LVL ENGINEERING STANDARDS		DATE	REVISION
SCF AREA DUCT INSTALLATION		05/20/01	1

PROJECT NO.		DRAWING NO.	
CHAPTER 6		ST-03040-6	
REVISION NO.		1	
DATE		11/14/14	
DRAWN BY		1	
CHECKED BY		2	
APPROVED BY		2	